



EN ISO/IEC 17065
S1-439



bmcertification

REGISTRATION CERTIFICATE

This is to approve

Tammer OÜ

Väike- Paala 4
11415 Tallinn
Estonia

Single and double leaf fire resisting and/or smoke control inward and outward opening internal insulated steel door sets intended for fire and/or smoke compartmentation meets the requirements of the A-MARK Scheme of factory production control (FPC) detailed in “BM Certification Scheme Technical Document of Verification of FPC and classification of products with higher reaction to fire or fire resistance requirements according to EN 13501-2” and EN 16034:2014. Performance of products is stated in appendix A, B, C, D and E.

Product name
SMU101 - EI30, SMU201 - EI30
SMU101- EI60, SMU201- EI60
SMU102 - EI60, SMU202 - EI60
SMU110 - EI120, SMU210 - EI120
SMU103 - EI60

This certificate was first issued on 07 December 2015 and will remain valid until the date of expiry shown on this certificate provided that the test methods and/or factory production control requirements included in the above document, do not change, and the manufacturing conditions in the plant are not modified significantly.



Jānis Švirksts
Member of the Board
BM Certification

Certificate number:
TT-PRS-093

Date of initial certification:
07 December 2015
Date of last issue:
30 November 2020
Date of expiry:
06 December 2022

BM Certification SIA, Jūrkalnes iela 15, Rīga, LV-1046, Latvija

This certificate remains the property of BM Certification. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM Certification, +371 67772135, info@bmcertification.com